



DELHI TRANSCO LIMITED

(A Govt. of NCT of Delhi Undertaking)

Office Of DGM(T)OS

1st Floor, 220 KV Sub-Stn Park Street Building,
New Delhi-110001

No. F.DTL/201/2022-23/DGM(OS)/F4/09

Date:12.04.2022

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Planning)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-1	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr. PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM(DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee


Sub: Agenda for 1stDelhi OCC Meeting (2022-23) to be held on 25.04.2022at 11:00 A.M. through video conferencing.

The 1stDelhi OCC meeting (2022-23) is scheduled to be held on dt.-25.04.2022,11:00 A.M and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing.**

Thanking You.

Sincerely yours,


12/04/2022
Hitesh Kumar
DGM(T)OS, DTL

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 01/2022-23

Date : **25.04.2022**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 KV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 12th Delhi OCC meeting (2021-22) held on dated 24.03.2022.

The 12th Delhi OCC meeting (2021-22) was held on 24.03.2022 through video conferencing in accordance with the agenda circulated vide letter dt: 14.03.2022. Minutes of the OCC meeting were issued on 28.03.2022 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of May-2022.

DTL proposed planned shutdowns for the month of May-2022 (Annexure-I).

(OCC may deliberate)

3. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 11.04.2022
1.	220KV TRAUMA CENTER- 33KV AIIIMS CKT	BRPL	29.01.22	UNDER BREAKDOWN.
2.	220KV OKHLA- 33kV ALAKNANDA CKT-1	BRPL	30.03.22	'Y' PHASE SINGLE CABLE FAULTY.
3.	220KV NARAINA- 33kV MAYAPURI CKT-2	BRPL	07.04.22	'B' PHASE SINGLE CABLE FAULTY.
4.	220KV PATPARGANJ- AKSHARDHAM	BYPL	05.04.22	'R' PHASE CABLE FAULTY.
5.	220KV IP BAY- 28- 33KV CONNAUGHT PLACE	NDMC	16.02.22	'Y' & 'B' PHASE CABLE TRIPPED ON E/F & O/C.
6.	220kV IP BAY 42- 33kV CONNAUGHT PLACE	NDMC	12.03.22	'Y' PHASE SINGLE CABLE FAULTY.

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 11.04.2022
7.	220KV TRAUMA CENTRE-33kV RACE COURSE CKT	NDMC	22.03.22	'R' PHASE CABLE FAULTY.
8.	220KV RIDGE VALLEY-66kV BAPUDHAM	NDMC	27.03.22	'R' PHASE CABLE FAULTY.
9.	220KV PARK STREET - 66KV DMRC CKT.-I&-II	DMRC	19.10.21	SHUT DOWN FOR GRID SHIFTING WORK AT DMRC END.
10.	220KV SHALIMAR BAGH-66KV PP-I CKT-II	TPDDL	04.03.22	'Y' PHASE CABLE FAULTY.
11.	400KV BAWANA, 315MVA ICT-II	DTL	30.03.21	315MVA ICT-II CAUGHT FIRE AND DAMAGED.
12.	AT PEERAGARHI: - 220/33KV 100MVA TRF.-I	DTL	10.07.21	TRIPPED ON DIFFERENTIAL. TX FAULTY.
13.	220KV LODHI ROAD - 33 KV VIDYUT BHAWAN, JLN STADIUM FEEDERS	DTL	29.11.21	AFFECTED DUE TO BOTH 33KV BUSES DEAD BECAUSE OF FIRE IN 33KV GIS
14.	AT MUNDKA: 315MVA ICT – IV	DTL	13.11.21	TRIPPED ON BUCHLOZ RELAY. 'R' PH. WINDING DAMAGED.
15.	220KV TRAUMA CENTER-33KV BHIKAJI KAMA PLACE	DTL	03.02.22	'R' PHASE PT DAMAGED.
16.	220KV OKHLA- 100 MVA-IV	DTL	03.02.22	TRIPPED ON DIFFERENTIAL.
17.	220KV SARITA VIHAR-20MVA TX-II	DTL	07.02.22	MADE OFF DUE TO HIGH CONTENT OF HYDROGEN GAS.
18.	220KV VASANT KUNJ-220/66kV 100 MVA-I	DTL	16.02.22	UNDER OVERHAULING.
19.	400KV BAMNAULI- 315MVA ICT-I	DTL	03.03.22	FOR DISMENTLING OF ICT.
