



No. F.DTL/201/2022-23/DGM(OS)/F4/ 63

Date: 15.09.2022

To,
All Members of Operation Co-ordination Committee

DTL	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Planning)	
SLDC	ED (SLDC) DGM (SO)	
TPDDL	HOD (PSC&AM) Sr. Manager (PSC)	
BRPL	AVP (SO)	
BYPL	AVP (SO)	
NDMC	Superintending Engineer, E-I	
IPGCL	AGM (T) Opr. GTPS	
PPCL	AGM (T) Opr.PPS-I AGM (T) Opr. PPS-III	
MES	AEE/M.SLDC Officer	
BBMB	Sr. Executive Engineer, O&M	
DMRC	Addl. GM (Elect.) Sr.DGM (Traction)	
GMR(DIAL)	GM (DIAL)	Special Invitee
N. Railways	Sr. DEE (TRD)	Special Invitee


Sub: Agenda for 6th Delhi OCC Meeting (2022-23) to be held on 23.09.2022 (Friday) at 11:00 A.M. through video conferencing.

The 6th Delhi OCC meeting (2022-23) is scheduled to be held on dt.- **23.09.2022, 11:00 A.M** and will be conducted through video conferencing as per attached agenda. **The link and password for joining the meeting is attached in mail.**

Members are hereby requested to make it convenient to attend the meeting via **video conferencing**.

Thanking You.

Sincerely yours,


DGM(T)OS, DTL 15-9-22

DELHI TRANSCO LIMITED

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

AGENDA FOR DELHI OCC MEETING NO. 06/2022-23

Date : **23.09.2022**
Time : **11:00 AM**
Venue : **Via Video conferencing**
In O/o-GM(O&M)-I, Delhi Transco Ltd.,
220 KV Sub-Stn Park Street Building,
New Delhi-110001

1. Confirmation of minutes of 5th Delhi OCC meeting (2022-23) held on dated 23.08.2022.

The 5th Delhi OCC meeting (2022-23) was held on 23.08.2022 through video conferencing in accordance with the agenda circulated vide letter dt: 17.08.2022. Minutes of the OCC meeting were issued on 25.08.2022 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

DTL Agenda:-

2. Proposed planned shutdowns of DTL for the month of October-2022.

DTL proposed planned shutdowns for the month of October-2022 (Annexure-I).

(OCC may deliberate)

PPCL Agenda:-

3. Shutdown requirement for overhauling of STG unit at PPS-I.

Pragati Power Station-I (PPS-I) proposed to take Steam Turbine Generator (STG) under shutdown for overhauling work as per schedule given below:-

S.No	Station	Unit Name	Proposed Work	Shutdown date
1.	PPS-I	STG	Overhauling	01.11.22 to 25.11.22

OCC is requested to approve the above shutdown.

(OCC may deliberate)

4. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 11.09.2022
1.	220KV PPK-II:- 66KV G5 MATIALA CKT-2	BRPL	08.09.22	'B' & 'Y' PHASE CABLE FAULTY
2.	220KV IP:- BAY 42- 33KV CONNAUGHT PLACE CKT-1	NDMC	18.05.22	Y & B PHASE SINGLE CABLE FAULTY
3.	220KV IP:- BAY 42- 33KV BAY NO 10 ELECTRIC LANE	NDMC	01.08.22	B PHASE TRIPPING.
4.	220KV HCML:- 33KV SCHOOL LANE	NDMC	06.09.22	R PHASE FAULTY.
5.	220KV NARELA:- 11KV INCOMER-2	DTL	27.08.22	UNDER BREAKDOWN.
6.	400KV TIKRI KALAN- 400/220KV 315MVA ICT-III	DTL	05.09.22	TX UNDER BREAKDOWN.
7.	220KV PEERAGARHI-TIKRI KALAN CKT-I	DTL	05.09.22	CKT UNDER BREAKDOWN.
8.	400KV BAWANA- 400/220KV 315MVA ICT-IV	DTL	08.09.22	TRIPPED ON PRV.
