

	<p>DELHI TRANSCO LIMITED (A Govt. of NCT of Delhi Undertaking) An ISO 9001:2015 certified company {Office of DGM(T)-OS} 1st Floor, Park Street Building, New Delhi-110001 Website:-www.dtl.gov.in</p>
---	--

No. F.DTL/201/2022-23/DGM(OS)/F4/46

Date:- 21.07.2022

**Subject: 4th Meeting of Delhi Operation Coordination Committee (2022-23)
- Minutes of Meeting.**

The 4th meeting of Delhi Operation Coordination Committee (OCC) was held on 18.07.2022 (Monday), 11:00 A.M and conducted through online mode.

The Minutes of Meeting are enclosed for confirmation and necessary action.

Minutes of Meeting are also available on DTL website, www.dtl.gov.in under the tab "News and Information"-OCC Meeting. (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

Thanking You.

Sincerely yours,

---Sd/--


(Hitesh Kumar)

Dy. General Manager (OS)

Delhi Transco Limited

Copy for favor of kind information to:

- (i) Secretary, DERC, Viniyamak Bhawan, C-Block, Shivalik, New Delhi-17
- (ii) OSD to CMD, DTL
- (iii) Director (Operation), DTL


21/07/2022
Dy. General Manager (OS)

To all members - - As per list enclosed - -

4th Meeting of Delhi Operation Coordination Committee (2022-23)- Minutes of Meeting

Distribution List:

DTL	1. General Manager (O&M)-I 2. General Manager (O&M)-II 3. General Manager (P&M, DM&S) 4. General Manager (Planning) 5. DGM (O&M) - North, East, West, South 6. DGM (Metering/Protection) 7. DGM (Planning)
SLDC	1. General Manager (SLDC) 2. DGM (SO)
TPDDL	HOD (PSC &AM), Sr. Manager (PSC)
BRPL	VP, AVP (SO)
BYPL	VP, AVP (SO)
NDMC	Superintending Engineer, E-1
IPGCL	AGM (T) Opr. GTPS
PPCL	1. AGM (T) Opr.PPS-I 2. AGM (T) Opr. PPS-III
MES	AEE/M.SLDC Officer
BBMB	Sr. Executive Engineer, O&M
DMRC	GM (Traction), Sr.DGM (Traction)
GMR(DIAL)	GM(DIAL)
N. Railways	Sr. DEE (TRD)

MINUTES OF 4th DELHI OCC MEETING

Date :	18.07.2022
Time:	11:00 AM
Venue:	Online Via Video conferencing O/o-GM(O&M)-I, Delhi Transco Ltd., 220 kV S/stn Park Street, New Delhi-01
	List of participants is enclosed as Annexure-I.

The Chairman, Delhi OCC welcomed the members/participants and congratulated them for successfully achieving the all time peak demand of Delhi i.e, 7695MW which came on 29.06.2022 at 15:10:41 hrs. He thanked all members for their efforts to maintaining the uninterrupted power supply of Delhi network throughout the year. Further, he requested to start the meeting as per circulated agenda.

1. Confirmation of minutes of 3rd Delhi OCC meeting (2022-23) held on dated 24.06.2022.

The 3rd Delhi OCC meeting (2022-23) was held on 24.06.2022 through video conferencing in accordance with the agenda circulated vide letter dt: 14.06.2022. Minutes of the OCC meeting were issued on 29.06.2022 and was uploaded on DTL website (http://dtl.gov.in/content/344_1_OCC-Meeting2021.aspx).

Members confirmed the Minutes of 3rd Delhi OCC meeting.

2. DTL Agenda:-Proposed planned shutdowns of DTL for the month of August-2022.

After detailed discussion with the members, OCC approved shutdowns subject to real time condition & consent from respective DISCOMs.

- All the shutdowns of general maintenance & tree trimming will be provided in a window available with SLDC when load is slightly low (i.e, 05:00AM to 09:00AM).
- At PPS-III, Bawana:- During the discussion of shutdown proposed by PPS-III, Bawana for GT#1, all concerned DISCOMs requested to shift this shutdown in the second fortnight of September-2022. After deliberation, OCC approved the shutdown from 25.09.2022 & advised PPS-III, Bawana to put up a revise schedule of shutdown in the upcoming NRPC for further approval. Concerned DISCOMs shall also submit their consent to SLDC on mail before the upcoming NRPC meeting scheduled for 21.07.2022.
- Shutdowns of 66kV bus bar at Najafgarh is deferred to September-2022.
- Due to high demand profile during week days, the shutdowns may be shifted on weekends on the basis of loading.

3. NDMC Agenda:-To provide regular supply to NDMC feeders & reduce the connecting load of other DISCOMs from Park Street during the Monsoon Parliament session.

It has been observed that NDMC is not in position to draw electric load from Park Street to various NDMC Feeders due to going on work of replacement of 100 MVA Tr. at Park Street since more than 02 months. It is well aware that the Monsoon Parliament Session is going to be commenced from 18th July 2022. Park Street supply is one of the main source of supply which is very close to the Parliament House.

Main Supply: Park Street to Nirman Bhawan ----> Krishi Bhawan----> Parliament House.
(Elect. Load)

Park Street to Baird Lane ----> Parliament House ----> (H.V.AC)

Standby Supply: 1. I.P. Bay 2 2. I.P. Bay 16 3. 220KV HCML
4. G.T. Vidyut Bhawan, etc.

It is requested that OCC may ensure for providing regular uninterrupted power supply from Park Street to all NDMC Feeders or make necessary arrangements for reducing the connecting load of other Discoms from Park Street feeders during the running of Monsoon Parliament Session. So that the supply of Parliament House might not be affected from NDMC Feeders.

OCC deliberation:-NDMC apprised OCC that Monsoon Parliament session has started from 18.07.2022 & shall continue till 12.08.2022. Park Street is the main source of supply for Parliament and requested to ensure the regular supply. NDMC added that IP Bay-2 cable has also become faulty in early morning on 18.07.2022 & team is tracing the fault location & revival date may be confirmed when its location get traced, hence it may take some time. After detailed deliberation, OCC informed NDMC that 100MVA Tx will be revived by 30.07.2022 & advised SLDC to manage the load and provide the uninterrupted supply to NDMC for parliament.

DERC has recommended to minimize the generation from Pragati, same can only be implemented when load from park street shifted to HCML. OCC advised NDMC to shift the main source of supply to Parliament from Park street to HCML as it is very close to Parliament and chances of fault in cable is minimum. OCC further advised NDMC to deliberate the issue with their management and further an agenda may be put up in the steering committee for shifting the main source of supply for Parliament from Park Street to HCML.

OCC also advised NDMC to share the list of damaged cables to SLDC and its restoration schedule so that continue power supply could be maintained.

4. Long/recent Outage/breakdown of elements in Delhi power system.

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Status of outage as on 18.07.2022
1.	220KV LODHI ROAD - 33 KV VIDYUT BHAWAN, JLN STADIUM FEEDERS	DTL	29.11.21	AFFECTED DUE TO BOTH 33KV BUSES DEAD BECAUSE OF FIRE IN 33KV GIS. Expected by 25.07.2022.
2.	220KV PARK STREET- 220/33KV 100MVA TX-II	DTL	30.05.22	TX UNDER BREAKDOWN. Expected by 30.07.2022.
3.	220KV GOPALPUR-160MVA TX	DTL	16.06.22	TX UNDER BREAKDOWN. Expected by 30.07.2022.

*** Long Outages were not updated by the System on the SLDC websites, therefore outages pertains to DISCOMs are not in the list. OCC advised SLDC to address the issue and get it resolved as soon as possible.**

The meeting ended with thanks to the Chair.
