



No. F.DTL/201/2023-24/DGM(OS)/F4/26

Date:-23.06.2023

Subject: 3rd Meeting of Delhi Operation Coordination Committee (2023-24)- Minutes of Meeting.

The 3rd meeting of Delhi Operation Coordination Committee (OCC) was held on 22.06.2023 (Thursday), 11:00 A.M. in the O/o GM(T)O&M-I DTL.

The Minutes of Meeting are enclosed for confirmation and necessary action.

Minutes of Meeting are also available on DTL website, www.dtl.gov.in under the tab "News and Information"-OCC Meeting.(http://dtl.gov.in/Content/359_1_OCC-Meeting2023.aspx).


Thanking You.

Sincerely yours,

--Sd--
(Hitesh Kumar)
Dy. General Manager (OS)
Delhi Transco Limited

Copy for favor of kind information to:

- (i) Secretary, DERC, ViniyamakBhawan, C-Block, Shivalik, New Delhi-17
- (ii) OSD to CMD, DTL
- (iii) Director (Operation), DTL


Dy. General Manager (OS)

To all members - - As per list enclosed - -

**3rd Meeting of Delhi Operation Coordination Committee (2023-24)- Minutes of Meeting
Distribution List:**

DTL	1. General Manager (O&M)-I 2. General Manager (O&M)-II 3. General Manager (P&M, DM&S) 4. General Manager (Planning) 5. DGM (O&M) - North, East, West, South 6. DGM (Metering/Protection) 7. DGM (Planning)
SLDC	1. General Manager (SLDC) 2.DGM (SO)
TPDDL	HOD (PSC &AM), Sr. Manager (PSC)
BRPL	VP, AVP (SO)
BYPL	VP, AVP (SO)
NDMC	Superintending Engineer, E-1
IPGCL	AGM (T) Opr. GTPS
PPCL	1. AGM (T) Opr.PPS-I 2. AGM (T) Opr. PPS-III
MES	AEE/M.SLDC Officer
BBMB	Sr. Executive Engineer, O&M
DMRC	GM (Traction), Sr.DGM (Traction)

MINUTES OF 3rd DELHI OCC MEETING

Date :	22.06.2023
Time:	11:00 AM
Venue:	O/o-GM(O&M)-I, Delhi Transco Ltd., 220 kV S/stn Park Street, New Delhi-01

The Chairman, Delhi OCC warmly welcomed the members/participants and commended on the efforts in maintaining the power supply in Delhi network. He emphasized that summer has already started and load demand started to grow therefore Chairman stressed to be vigilant of weather forecast and all efforts should be made to properly monitor the system and take immediate action towards any abnormality. Chairman requested to start the meeting as per circulated agenda.

1. Confirmation of minutes of 2nd Delhi OCC meeting (2022-23) held on date 22.06.2023.

The 2nd Delhi OCC meeting (2022-23) was held on 23.05.2023 physically in the O/o GM(T)O&M-I in accordance with the agenda circulated vide letter dt: 15.05.2023. Minutes of the OCC meeting were issued on 30.05.2023 and were uploaded on DTL website (http://dtl.gov.in/Content/359_1_OCC-Meeting2023.aspx).

OCC Deliberation: - Members confirmed the Minutes of 2nd Delhi OCC meeting.

2. DTL Agenda:-

2.1 Proposed planned shutdowns of DTL for the month of July-2023.

DTL proposed planned shutdowns for the month of July-2023 were discussed in the meeting. After detailed discussion with the members, OCC approved shutdowns subject to real time condition & consent from respective DISCOMs. OCC requested to allow shutdown only during morning period up to 9AM only.

1. OCC discussed shutdown for complete 33 kV GIS at 220 kV Lodhi Road for commissioning of second phase 33 kV GIS Switchgear panels. OCC allowed shutdown and directed O&M/DTL to complete strictly within time schedule.

2. OCC discussed agenda put up by NHAI for shutdown of Bawana-Kanjhawla Ckt I&II, Kanjhawala-Tikrikalan-Najafgarh Circuits for erection of Monopole, stringing work and foundation work. OCC allowed shutdown subjected to energization of 315 MVA ICT-III at Tikrikalan as below:-

Sr No	Name of the Line	Shutdown Required Remarks	Circuit	Time	Remarks	OCC Remarks
1	220kV D/C Bawana - Kanjhawala Line, Ch. 15+000 to 16+400	26th June 2023	CKT- I &II	As per Site Requirement	Foundation work @ Loc. No. 189	Allowed on 25.06.2023

2	220kV D/C Kanjhawala - Najafgarh-Tikrikalan Line, Ch. 20+900 to 21+400	28th June 2023 to 30th June 2023	CKT- I &II	As per Site Requirement	Erection and Stringing Work @ Loc. No. 173	Allowed from 15.07.2023 to 17.07.2023
3	220kV D/C Bawana - Kanjhawala Line, Ch. 15+000 to 16+400	08th July 2023 to 12th July 2023	CKT- I &II	As per Site Requirement	Erection Work of Monopole (06 Nos) And Stringing Work	Deferred
4	220kV D/C Kanjhawala - Najafgarh Line, Ch. 20+400 to 20+800	15th July 2023 to 21th July 2023	CKT-1 &II	As per Site Requirement	Erection Work of Monopole (04 Nos) near Railway Crossing and Stringing Work	Deferred

3. OCC discussed and allowed Shutdown of Bamnauli - PPK I Ckt I&II from 22.06.2023 to 24.06.2023. Please note that temporary arrangement has been made for reliable supply of PPK-I. In this arrangement, BAMNAULI-PPK3 Circuit II (at tower no 21) is connected to Bamnauli - PPK I circuit I (at tower no 25). Therefore Supply at PPK-I will be available through Bamnauli-PPK3 Circuit II (till tower no 21) and then Bamnauli - PPK I circuit I (from tower no 25). Bamnauli -PPK3 Circuit II will be off at PPK-III station. O&M/DTL also informed that Dwarka-PPK I circuit I will also be energized by 22.06.2023, 8:00PM.

4. Manager (T) O&M S-5 raised an issue during the OCC regarding the charging of 220 kV Sarita Vihar-Maharani Bagh Circuit and 220 kV Sarita Vihar-Pragati circuit as the line will be cleared for energisation by M/s NHAI and M/s PWD along with necessary electrical clearance by 27.06.2023. This issue was deliberated in the OCC and after discussion the Chairman OCC directed for continuance of present temporary arrangement as discussed in 2nd Delhi OCC 2023-24 as per the SLDC Agenda, to increase the reliability of power supply in central-east Delhi region as 220 kV Wazirabad-Geeta Colony Circuit is under outage and this arrangement also balances load flow in the circuits from 220 kV Maharani Bagh to 220 kV Pragati Stn. The O&M deptt further informed that these lines i.e. from tower no 49 to 12 A are vulnerable to theft and have unauthorized constructions.

Further OCC advised O&M to back charge 220 kV Sarita Vihar-Maharani Bagh Circuit and 220 kV Sarita Vihar-Pragati circuit (from tower no 49 to 12A) from 220 kV Sarita Vihar after ensuring proper isolation at tower no 12A among 220 kV Maharani Bagh-Pragati Circuit (temporary arrangement, temporary connection was done at tower no 12A), 220 kV Sarita Vihar-Maharani Bagh Circuit (from tower no 49 to 12A) and 220 kV Sarita Vihar-Pragati Circuit (from tower no 49 to 12A). The necessary line protection for this arrangement may be discussed and implemented in coordination with the protection deptt/DTL & O&M/DTL.

3. PPCL Agenda:-

3.1 Trippings at Pragati Power Station– 1 (PPS-1) due to grid disturbance

This is to inform you that due to grid disturbance on 17/05/2023 and 01/06/2023, the machines of PPS-I tripped as the 220 KV Bus became dead due to tripping of multiple lines of Delhi Transco Ltd. On dated 17/05/2023, load on GT # 2 was 97 MW and on STG was 51 MW while on 01/06/2023, load on GT # 2 was 102 MW and on STG was 53MW.

Such types of repeated trippings is a matter of concern as this is not only resulting in loss of generation & but also frequent start stops of machines which is detrimental to the health of machines. This is also resulting in financial loss to the PPS-I.

In view of above, it is requested to take necessary action to avoid such types of trippings in future.

OCC Deliberation:- OCC requested PPCL to share relay indications and tripping related data to DTL/Protection team and further analyse the reason of tripping with DTL/protection dept.

4. BYPL Agenda:-

4.1 BYPL requests DTL to share the status of 220kV Harsh vihar to 220kV Preet vihar ckt-1 which is already under Shutdown since January-2023.

Due to summer season Grid loading is increasing day by day load wouldn't be managed in case of any tripping of available circuit resultant major load shedding. The circuit should bring in the network As soon as possible.

Due to unavailability of the circuit force power scheduling is also being carried out by Pragati Power Station to maintain line loading the cost of Pragati-1 is around Rs.10.28 per unit which is highest among the other plants.

Therefore, it is not commercially viable to schedule such high cost plant which is unnecessary burden on consumers of Delhi.

OCC Deliberation:- DTL/O&M informed OCC that material required for revival of 220kV Harsh vihar to 220kV Preet vihar ckt-1 is being imported by OEM. Further O&M/DTL informed that the circuit will be energized latest by 31.07.2023. OCC requested O&M/DTL to expedite the process for early revival of the circuit.

4.2 BYPL requests DTL to share the status of 220kV Wazirabad to 220kV Geeta Colony ckt-1 which is already under Breakdown since 17-May-2023. Grid loading is obviously higher side during summer so major load shedding will be involved in case of any Breakdown of present available circuits. The circuit should bring in the network As soon as possible.

OCC Deliberation:- DTL/O&M informed OCC that tender of Contract to attend breakdown of 220 kV Wazirabad- Geeta Colony Ckt-I is under process and the circuit will be energized by 02.07.2023.

5. TPDDL Agenda



TPDDL / CEO/ 2023-24
31st May 2023

The Director (Operations)
Delhi Transco Limited
Shakti Sadan, Kotla Marg
New Delhi- 110002

Subject: DTL Network Constraint & Support for Ongoing Summer FY 23-24

Dear Sir,

Greetings from Tata Power-DDL !

This is in continuation to our earlier letter no. TPDDL/Chief (BD, C, S & TS)/2023-24/07 dated 25th April 23, regarding the support required from the Delhi Transco Ltd. for network constraints at 220 KV for summer of FY 23-24. We would like to bring to your kind notice the delay in commissioning of 100 MVA Power Transformer at 220 KV Sabzi Mandi Grid.

1. It was assured by DTL team during meeting dated 06th Mar' 23 that this transformer shall be available for taking load by 15th of April'23.
2. Also, during Operation Coordination Committee meeting held on 25th April'23, it was deliberated that the transformer shall be energized by 15th June' 23.

It is worthwhile to mention that 220 KV Sabzi Mandi Grid is feeding various important installations like Delhi University, Hospitals & other important customers and it is very critical to maintain reliable supply in the area. The concern regarding the non-availability of 100 MVA transformer at Sabzi Mandi is being expressed by TPDDL consistently during various interactions for summer preparedness including Hon'ble DERC, Principal Secretary (Power) & Hon'ble Power Minister, Govt. of NCT Delhi.

In view of above, it is requested for your kind intervention & support to ensure reliable power supply to our customers by way of early commissioning and energization of Power Transformer at 220 KV Sabzi Mandi Grid as soon as possible. This would go a long way to provide our customers with reliable & uninterrupted supply.

With best regards,

Yours sincerely,
Ganesh Srinivasan
Ganesh Srinivasan



TATA POWER DELHI DISTRIBUTION LIMITED
(A Tata Power and Delhi Government Joint Venture)
Corporate Office : NDPL House Hudson Lines Kingsway Camp Delhi - 110 009
Tel. +91 11 66112200 66112222, Dir.: +91 11 66112202, Fax: +91 11 27468042
E-mail : ceo.office@tatapower-ddl.com Website : www.tatapower-ddl.com
CIN No. : U40109DL2001PLC111526



Director (Operations)
please put up a sheet what plan have in case of disubst at PTL
8/6/23

G.M. (O&M)-I
urgent n.a. please.
Mpls 5/6/23

OCC Deliberation:- O&M/DTL informed OCC that New Transformer is being shifted to Subzi Mandi and will be energized by 20.08.2023. OCC further requested TPDDL to work on Ring network for feeders feeding VVIP areas in line with BRPL. TPDDL shall update the status of the same in next OCC meeting.

4. Long/recent Outage/breakdown of elements in Delhi power system.




















Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Date of Restoration	Status of outage
1	66KV MDK TO NGL	BRPL	26-04-23	07-06-2023	Y PHASE CABLE FAULTY
2	66KV PPK-2 TO HASTAL CKT-2	BRPL	04-05-23	19-05-2023	R PHASE SINGLE CABLE FAULTY
3	66KV PARK STREET TO MOTIA KHAN CKT-1	BYPL	10-04-23	30-06-2023	ALL PHASE SINGLE CABLE FAULTY
4	400KV TIKRI KALAN-400/220KV 315MVA ICT-III	DTL	05.09.22	23-06-23	TX UNDER BREAKDOWN.
5	220KV PEERAGARHI-TIKRI KALAN CKT-I	DTL	05.09.22	28-05-23	CABLE UNDER B/D.
6	220KV SUBZI MANDI:- 100MVA -I	DTL	04.01.23	20-08-23	TX UNDER B/D.
7	220KV HARSH VIHAR – PREET VIHAR CKT-I	DTL	20.01.23	31-07-23	ISSUE IN B PHASE CT.
8	220KV MAHARANI BAGH –MASJID MOTH CKT-II	DTL	29.01.23	31-07-23	CABLE CAUGHT FIRE.
9	220KV BAMNAULI-220KV DIAL CKT-II	DTL	31.01.23	31-07-23	CKT UNDER BREAKDOWN.

10	220KV LODHI ROAD:-33KV VIDYUT BHAWAN, JLN STADIUM FEEDERS	DTL	29.11.21	26-06-23	AFFECTED DUE TO FIRE IN 33KV GIS at LODHI ROAD.
11	220 KV SARITA VIHAR -20 MVA TRANSFORMER	DTL	01.08.22	31-07-23	DUE TO HIGH H2 GAS.

Meeting ended with thanks to Chair

3rd Delhi OCC Meeting-June 2023 Dated 22.06.2023

S No	Name	Designation	Organisation	Signature
1.	RAJAT VIJAY	Dy Mgr (T) OS	DTL	
2.	Naveen Guel	DGMCD West	DTL	
3	Sumit Kumar	AGM (T)	PPCL	
4	Ashok Kumar Meena	DM (T)	PPCL	
5	S.K. Sinha	AGM (T)	SLDC	
6	ANIL BOHARA	Head System Operation	BRPL	
7	Kapil Kumar	DGM (PSC)	TPDDL	
8.	Anil Vaishy	AVP (PCC)	BYPL	
9.	Kalchmi Chand	Manager (T) W-1	DTL	
10.	Paritosh Joshi	Sr. Mgr (T) OS	DTL	
11.	Anuj Kr. Gokhale	AGMCD North	DTL	
12	S.K. Garg	DM (T) South	DTL	
13	Devendra Sharma	GM BYPL	BSES, YPL	
14	M. Kishore Babu	GM BRPL	BRPL	
15	Gusmukh Singh	Sr. Manager	TPDDL	
16	Ghanshyam Yadav	AMCT (EP)	DTL	
17	SHANKAR KUMAR	Sr. Mgr. (E) Protection-III	DTL	
18	Subhash Chandra Jha	Sr. Mgr (T) W-04	DTL	 22/06/23
19	ADITYA P.S. SHISHODIA	Manager (T)	DTL	
20	U K PRA SOON	AM (T) ML	DTL	