



No. F.DTL/201/2023-24/DGM(OS)/F4/ 25

Date: 19-06-2023

To,  
**All Members of Operation Co-ordination Committee**

<b>DTL</b>	General Manager (O&M)-I, Chairman OCC General Manager (O&M)-II General Manager (P&M, DM&S) General Manager (Planning) DGM (O&M) - North, East, West, South DGM (M/P) DGM (Planning)
<b>SLDC</b>	ED (SLDC) DGM (SO)
<b>TPDDL</b>	HOD (PSC&AM) Sr. Manager (PSC)
<b>BRPL</b>	AVP (SO)
<b>BYPL</b>	AVP (SO)
<b>NDMC</b>	Superintending Engineer, E-1
<b>IPGCL</b>	AGM (T) Opr. GTPS
<b>PPCL</b>	AGM (T) Opr. PPS-I AGM (T) Opr. PPS-III
<b>MES</b>	AEE/M.SLDC Officer
<b>BBMB</b>	Sr. Executive Engineer, O&M
<b>DMRC</b>	Addl. GM (Elect.) Sr.DGM (Traction)


**Sub: Agenda for 3<sup>rd</sup> Delhi OCC Meeting (2023-24) to be held on 22.06.2023 (Thursday) at 11:00 A.M.**

The 3<sup>rd</sup> Delhi OCC meeting (2023-24) is scheduled to be held on dt.- **22.06.2023, 11:00 A.M** in the office of GM(O&M-I), Delhi Transco Limited, 220kV Sub-Stn Park Street, Opp. Talkatora Stadium, near RML Hospital, New Delhi-110001.

Members are hereby requested to make it convenient to attend the meeting.

Thanking You.

Sincerely yours,

  
19/06/2023  
Hitesh Kumar  
DGM(T)OS, DTL

## **DELHI TRANSCO LIMITED**

(Regd. Office: Shakti Sadan, Kotla Road, New Delhi-110002)

### **AGENDA FOR DELHI OCC MEETING NO. 3/2023-24**

**Date** : **22.06.2023**  
**Time** : **11:00 AM**  
**Venue** : In O/o-GM(O&M)-I, Delhi Transco Ltd.,  
220 KV Sub-Stn Park Street Building,  
New Delhi-110001

#### **1. Confirmation of minutes of 2<sup>nd</sup> Delhi OCC meeting (2022-23) held on dated 23.05.2023.**

The 2<sup>nd</sup> Delhi OCC meeting (2022-23) was held on 23.05.2023 physically in the O/o GM(T)O&M-I in accordance with the agenda circulated vide letter dt: 15.05.2023. Minutes of the OCC meeting were issued on 30.05.2023 and was uploaded on DTL website ([http://dtl.gov.in/Content/359\\_1\\_OCC-Meeting2023.aspx](http://dtl.gov.in/Content/359_1_OCC-Meeting2023.aspx)).

#### **DTL Agenda:-**

#### **2. Proposed planned shutdowns of DTL for the month of July-2023.**

DTL proposed planned shutdowns for the month of July-2023 (Annexure-I).

**(OCC may deliberate)**

#### **3. PPCL Agenda:-**

##### **3.1 Trippings at Pragati Power Station– 1 (PPS-1) due to grid disturbance**

This is to inform you that due to grid disturbance on 17/05/2023 and 01/06/2023, the machines of PPS-I tripped as the 220 KV Bus became dead due to tripping of multiple lines of Delhi Transco Ltd. On dated 17/05/2023, load on GT # 2 was 97 MW and on STG was 51 MW while on 01/06/2023, load on GT # 2 was 102 MW and on STG was 53MW.

Such types of repeated trippings is a matter of concern as this is not only resulting in loss of generation & but also frequent start stops of machines which is detrimental to the health of machines. This is also resulting in financial loss to the PPS-I.

In view of above, it is requested to take necessary action to avoid such types of trippings in future.

**(OCC may deliberate)**

#### **4. BYPL Agenda:-**

##### **4.1 BYPL requests DTL to share the status of 220kV Harsh vihar to 220kV Preet vihar ckt-1 which is already under Shutdown since January-2023.**

Due to summer season Grid loading is increasing day by day load wouldn't be managed in case of any tripping of available circuit resultant major load shedding. The circuit should bring in the network As soon as possible.

Due to unavailability of the circuit force power scheduling is also being carried out by Pragati Power Station to maintain line loading the cost of Pragati-1 is around Rs.10.28 per unit which is highest among the other plants.

Therefore, it is not commercially viable to schedule such high cost plant which is unnecessary burden on consumers of Delhi.

**4.2 BYPL requests DTL to share the status of 220kV Wazirabad to 220kV Geeta Colony ckt-1 which is already under Breakdown since 17-May-2023. Grid loading is obviously higher side during summer so major load shedding will be involved in case of any Breakdown of present available circuits. The circuit should bring in the network As soon as possible.**

**(OCC may deliberate)**

#### **5. TPDDL Agenda**

**P.T.O**



Ganesh Srinivasan  
Chief Executive Officer

TPDDL / CEO/ 2023-24  
31<sup>st</sup> May 2023

The Director (Operations)  
Delhi Transco Limited  
Shakti Sadan, Kotla Marg  
New Delhi- 110002

*Director (Operations)  
please put up a sheet what plan have in case of disaster at DTL substn.*



*G.H. (O&M)-I  
urgent m.a. from.  
Maha 5/6/23*

**Subject: DTL Network Constraint & Support for Ongoing Summer FY 23-24**

Dear Sir,

Greetings from Tata Power-DDL !

This is in continuation to our earlier letter no. TPDDL/Chief (BD, C, S & TS)/2023-24/07 dated 25<sup>th</sup> April 23, regarding the support required from the Delhi Transco Ltd. for network constraints at 220 KV for summer of FY 23-24. We would like to bring to your kind notice the delay in commissioning of 100 MVA Power Transformer at 220 KV Sabzi Mandi Grid.

1. It was assured by DTL team during meeting dated 06<sup>th</sup> Mar' 23 that this transformer shall be available for taking load by 15<sup>th</sup> of April'23.
2. Also, during Operation Coordination Committee meeting held on 25<sup>th</sup> April'23, it was deliberated that the transformer shall be energized by 15<sup>th</sup> June' 23.

It is worthwhile to mention that 220 KV Sabzi Mandi Grid is feeding various important installations like Delhi University, Hospitals & other important customers and it is very critical to maintain reliable supply in the area. The concern regarding the non-availability of 100 MVA transformer at Sabzi Mandi is being expressed by TPDDL consistently during various interactions for summer preparedness including Hon'ble DERC, Principal Secretary (Power) & Hon'ble Power Minister, Govt. of NCT Delhi.

In view of above, it is requested for your kind intervention & support to ensure reliable power supply to our customers by way of early commissioning and energization of Power Transformer at 220 KV Sabzi Mandi Grid as soon as possible. This would go a long way to provide our customers with reliable & uninterrupted supply.

With best regards,

Yours sincerely,

Ganesh Srinivasan



**TATA POWER DELHI DISTRIBUTION LIMITED**

(A Tata Power and Delhi Government Joint Venture)  
Corporate Office : NDPL House Hudson Lines Kingsway Camp Delhi - 110 009  
Tel. +91 11 66112200 66112222, Dir.: +91 11 66112202, Fax: +91 11 27468042  
E-mail : ceo.office@tatapower-ddl.com Website : www.tatapower-ddl.com  
CIN No. : U40109DL2001PLC111526



CMMI SVC / 5<sup>th</sup>

**4. Long/recent Outage/breakdown of elements in Delhi power system.**

Members may update the latest status of following Long/Recent Outage/Breakdowns of elements in the Delhi Power system as under:

S. no.	Element's Name	Utility	Date of outage	Date of Restoration	Status of outage
1	66KV MDK TO NGL	BRPL	26-04-23	30-05-23	Y PHASE CABLE FAULTY
2	66KV PPK-2 TO HASTAL CKT-2	BRPL	04-05-23	30-05-23	R PHASE SINGLE CABLE FAULTY
3	66KV PARK STREET TO MOTIA KHAN CKT-1	BYPL	10-04-23	30-05-23	ALL PHASE SINGLE CABLE FAULTY
4	400KV TIKRI KALAN-400/220KV 315MVA ICT-III	DTL	05.09.22	10-06-23	TX UNDER BREAKDOWN.
5	220KV PEERAGARHI-TIKRI KALAN CKT-I	DTL	05.09.22	28-05-23	CABLE UNDER B/D.
6	220KV SUBZI MANDI:- 100MVA -I	DTL	04.01.23	30-06-23	TX UNDER B/D.
7	220KV HARSH VIHAR – PREET VIHAR CKT-I	DTL	20.01.23	29-05-23	ISSUE IN B PHASE CT.
8	220KV MAHARANI BAGH –MASJID MOTH CKT-II	DTL	29.01.23	31-07-23	CABLE CAUGHT FIRE.
9	220KV BAMNAULI-220KV DIAL CKT-II	DTL	31.01.23	31-07-23	CKT UNDER BREAKDOWN.
10	220KV LODHI ROAD:-33KV VIDYUT BHAWAN, JLN STADIUM FEEDERS	DTL	29.11.21	15-06-23	AFFECTED DUE TO FIRE IN 33KV GIS at LODHI ROAD.
11	220 KV SARITA VIHAR -20 MVA TRANSFORMER	DTL	01.08.22	31-07-23	DUE TO HIGH H2 GAS.

**(OCC may deliberate)**

\*\*\*\*\*